



### Fire Lane Identification – Red Curbs

#### STANDARD CURB




#### ROLLED CURB



#### NO CURB

2% Drainage Swale



1. Curbs shall be painted OSHA safety red
2. "FIRE LANE – NO PARKING" shall be painted on top of curb in 3 inch white lettering at a spacing of 30 feet or portion thereof